

CEM - 2009 (Quarterly)

Chevron Canada Ltd.
Permit: 0117 / Due Date: Apr 30 2009

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	January 1 - March 31
Total Hours of Data Collected:	2114 hrs
Permitted Flow Limit:	96 m3/min
Average Measured CEM Flow:	
Contaminant Permit Limit Value:	630 kg/day
Minimum Hourly Average Test Result:	166 kg/day
Date/Time of Minimum Hourly Average Test Result:	Feb 22 2009
Maximum Hourly Average Test Result:	548 kg/day
Date/Time of Maximum Hourly Average Test Result:	Mar 06 2009
Average of Test Results Over the Quarter:	284 kg/day
98th Percentile Value:	402 kg/day
Data Recovery:	98.9 %
Comments:	