

CEM - 2011 (Quarterly)

Chevron Canada Ltd.
Permit: 0117 / Due Date: Apr 30 2011

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	January 1 - March 31
Total Hours of Data Collected:	2143 hrs
Permitted Flow Limit:	96 m3/min
Average Measured CEM Flow:	
Contaminant Permit Limit Value:	630 kg/day
Minimum Hourly Average Test Result:	37 kg/day
Date/Time of Minimum Hourly Average Test Result:	Jan 23 2011
Maximum Hourly Average Test Result:	303 kg/day
Date/Time of Maximum Hourly Average Test Result:	Jan 28 2011
Average of Test Results Over the Quarter:	215 kg/day
98th Percentile Value:	297 kg/day
Data Recovery:	99.2 %
Comments:	