

CEM - 2012 (Quarterly)

Chevron Canada Ltd.
Permit: 0117 / Due Date: Jan 30 2012

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	October 1 - December 31
Total Hours of Data Collected:	2186 hrs
Permitted Flow Limit:	96 m3/min
Average Measured CEM Flow:	
Contaminant Permit Limit Value:	630 kg/day
Minimum Hourly Average Test Result:	112 kg/day
Date/Time of Minimum Hourly Average Test Result:	Nov 09 2011
Maximum Hourly Average Test Result:	270 kg/day
Date/Time of Maximum Hourly Average Test Result:	Dec 03 2011
Average of Test Results Over the Quarter:	161 kg/day
98th Percentile Value:	233 kg/day
Data Recovery:	99 %
Comments:	