

# CEM - 2011 (Quarterly)

Chevron Canada Ltd.  
Permit: 0117 / Due Date: Jul 30 2011

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	April 1 - June 30
Total Hours of Data Collected:	2158 hrs
Permitted Flow Limit:	96 m3/min
Average Measured CEM Flow:	
Contaminant Permit Limit Value:	630 kg/day
Minimum Hourly Average Test Result:	146 kg/day
Date/Time of Minimum Hourly Average Test Result:	Jun 30 2011
Maximum Hourly Average Test Result:	364 kg/day
Date/Time of Maximum Hourly Average Test Result:	Jun 11 2011
Average of Test Results Over the Quarter:	240 kg/day
98th Percentile Value:	340 kg/day
Data Recovery:	98.8 %
Comments:	