

# CEM - 2010 (Quarterly)

Chevron Canada Ltd.  
Permit: 0117 / Due Date: Oct 30 2010

| 22R - Sulphur recovery unit (SRU) incinerator    |                       |
|--|-----------------------|
| Sulphur Oxides                                   |                       |
| Test Date Range:                                 | July 1 - September 30 |
| Total Hours of Data Collected:                   | 1872 hrs              |
| Permitted Flow Limit:                            | 96 m3/min             |
| Average Measured CEM Flow:                       |                       |
| Contaminant Permit Limit Value:                  | 630 kg/day            |
| Minimum Hourly Average Test Result:              | 0 kg/day              |
| Date/Time of Minimum Hourly Average Test Result: | Sep 21 2010           |
| Maximum Hourly Average Test Result:              | 324 kg/day            |
| Date/Time of Maximum Hourly Average Test Result: | Sep 14 2010           |
| Average of Test Results Over the Quarter:        | 199 kg/day            |
| 98th Percentile Value:                           | 273 kg/day            |
| Data Recovery:                                   | 99.4 %                |
| Comments:  |                       |