

CEM - 2012 (Quarterly)

Chevron Canada Ltd.
Permit: 0117 / Due Date: July 30, 2012

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	April 1 - June 30
Total Hours of Data Collected:	2142.00 hours
Permitted Flow Limit:	96.00 m3/min
Contaminant Permit Limit:	630.0000 kg/day
Minimum Hourly Average Test Result:	125.000 kg/day
Date/Time of Minimum Hourly Average Test Result:	April 30, 2012
Maximum Hourly Average Test Result:	495.000 kg/day
Date/Time of Maximum Hourly Average Test Result:	June 15, 2012
Average of Test Results Over the Quarter:	224.000 kg/day
98th Percentile Value:	357.000 kg/day
Data Recovery:	98.100 %
Comments:	