

CEM - 2012 (Quarterly)

Chevron Canada Ltd.
Permit: 0117 / Due Date: October 30, 2012

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	July 1 - September 30
Total Hours of Data Collected:	2152.00 hours
Permitted Flow Limit:	96.00 m3/min
Contaminant Permit Limit:	630.0000 kg/day
Minimum Hourly Average Test Result:	99.000 kg/day
Date/Time of Minimum Hourly Average Test Result:	July 26, 2012
Maximum Hourly Average Test Result:	351.000 kg/day
Date/Time of Maximum Hourly Average Test Result:	August 16, 2012
Average of Test Results Over the Quarter:	216.000 kg/day
98th Percentile Value:	303.000 kg/day
Data Recovery:	97.500 %
Comments:	