

CEM - 2013 (Quarterly)

Chevron Canada Ltd.

Permit: 0117 / Due Date: January 30, 2013

22R - Sulphur recovery unit (SRU) incinerator	
Sulphur Oxides	
Test Date Range:	October 1 - December 31
Total Hours of Data Collected:	2154.00 hours
Permitted Flow Limit:	96.00 m3/min
Contaminant Permit Limit:	630.0000 kg/day
Minimum Hourly Average Test Result:	52.000 kg/day
Date/Time of Minimum Hourly Average Test Result:	October 17, 2012
Maximum Hourly Average Test Result:	254.000 kg/day
Date/Time of Maximum Hourly Average Test Result:	October 03, 2012
Average of Test Results Over the Quarter:	151.000 kg/day
98th Percentile Value:	243.000 kg/day
Data Recovery:	97.600 %
Comments:	